# CITY OF NEWTON, MASSACHUSETTS

#### PURCHASING DEPARTMENT

purchasing@newtonma.gov Fax (617) 796-1227

May 17, 2011

# **ADDENDUM #1**

## **INVITATION FOR BID #11-82**

### NPS - NNHS TV STUDIO #203 LIGHTING

THIS ADDENDUM IS TO: Answer the following Question from the Pre-Bid meeting:

Q1. What is the height from the floor to the grid?

A1. The height from the floor to the grid is 12 feet.

All other terms and conditions of this bid remain unchanged

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.

Thank you.

Rositha Durham

Chief Procurement Officer